

學校用電比對表：

月分	學 年					
	09 / 10	10 / 11	11/12	12/13	13 / 14	14 / 15
8		44100	<b>51120</b>	55160	27919	
9	55070	51100	43070	32010	48741	55869
10	49120	46060	43360	43590	52578	45931
11	51280	39900	40680	48610	33610	30466
12	23440	40210	41330	40980	25469	28115
1	23440	9420	3800	7090	19999	17478
2	24630	23210	26460	23640	26398	20509
3	35751	26110	28930	27450	21982	21526
	<b>11 to 3 (158541)</b>	<b>11 to 3 (138850)</b>	<b>11 to 3 (141200)</b>	<b>11 to 3 ( 147770 )</b>	<b>11 to 3 ( 127458 )</b>	<b>11 to 3 (118094)</b>
4	30190	23410	25500	28680	30860	27723
5	52630	50160	67230	51130	40726	53922
6	36810	34980	44870	33150	55526	
<b>Total</b>	<b>382361</b> (up to 6/2010)	<b>344560</b> (from 9/2010 to 6/2011)	<b>365230</b> (from 9/2011 to 6/2012)	<b>336330</b> (from 9/2012 to 6/2013)	<b>355889</b> ( from 9/2013 to 6/2014 )	
<b>% Change as compared with <u>previous</u> <u>year</u></b>	<b>-7.2 %</b> (up to 6/2010)	<b>-9.9 %</b> (up to 6/2011)	<b>+6.0 %</b> ( up to 6/2012 )	<b>-7.9 %</b> ( up to 6/2013 )	<b>+5.8 %</b> ( up to 6/2014 )	
<b><u>Target for next year</u></b>	<b>No increment</b>	<b>No increment</b> (as more electrical appliances have been installed in school after improvement scheme )	<b>The total consumption to be restored to 10/11 level</b>	<b>The total consumption is less than that of 12/13</b>		

